

PLANT INFLUENT				PLANT EFFLUENT @DMS																	REMARKS				
DAY	INF. MGD	EFF. MGD	Molalla River CFS	pH	BOD mg/L	TSS mg/L	Temp	pH	Max Temp	Min DO	NH3	BOD mg/L	BOD % Rem	BOD Disch. lbs	TSS mg/L	TSS % Rem	TSS Disch. Lbs	Chlorine Used lbs	Cl2 Res	Total Colif	Turbidity	MOL 1400-DO	River 1800 Temp	RAIN inch	Day
1	0.921			7.2	169	151	15.1															11.5	11.4	0.60	1
2	1.293			6.9			15.0															11.2	10.7	0.40	2
3	1.290			7.2	151	120	14.9															11.9	10.2	0.20	3
4	1.147			6.8			14.4															11.9	10.7	0.15	4
5	1.084																							0.00	5
6	1.057																							0.00	6
7	0.994			7.1			15.3															10.9	14.5	0.00	7
8	0.974			7.0	150	148	15.5															10.7	15.3	0.00	8
9	0.930			7.2			15.4															11.5	14.6	0.00	9
10	0.925			7.0	139	140	15.6															11.0	13.9	0.00	10
11	0.948			7.2			15.7															11.2	13.1	0.00	11
12	0.982																							0.07	12
13	0.948																							0.01	13
14	0.929			7.0			15.9															10.7	13.0	0.00	14
15	0.925	0.446		7.2	163	173	16.1											19				10.5	16.0	0.00	15
16	0.886	0.369		7.2			16.3											16				10.2	16.2	0.00	16
17	0.861	0.514		7.0	130	170	15.9											18			0.68	10.4	16.2	0.00	17
18	0.864	0.959		7.1			16.2	7.3			7.6							31	0.04		1.17	10.3	15.9	0.08	18
19	0.883	0.724						7.3										25	0.65	<1	1.48			0.01	19
20	0.956	0.206																7		<1	2.01			0.15	20
21	0.911	0.609		7.3			16.3	7.1										18	0.70	<1	0.68	11.3	12.0	0.00	21
22	0.862	1.003		7.2		171	16.3	6.9			9.9							30	1.00	<1	0.60	11.9	12.5	0.00	22
23	0.823	0.967		7.3			16.5	6.7										36	1.20		0.65	10.6	14.8	0.01	23
24				7.1			16.8	6.7											1.40						24
25																									25
26																									26
27																									27
28																									28
29																									29
30																									30
31																									31
Total	22.393	5.797																200						1.68	TOTAL
MAX	1.293	1.003		7.3	169	173	16.8	7.3			9.9	0.0	0	0	0.0	0	0	36	1.40					0.60	MAX
MIN	0.823	0.206		6.8	130	120	14.4	6.7			7.6	0.0	0	0	0.0	0	0	7	0.04					0.00	MIN
AVG	0.974	0.644	#DIV/0!	7.1	150	153	15.7	7.0	#DIV/0!	#DIV/0!	8.8	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	22	0.83	#DIV/0!	1.0	11.0	13.6	0.07	AVG
PERMIT STAND								6-9				10mg/L	80%	160 lbs/day	10mg/L	80%	160 lbs/day			2.2	2.0/Daily Average				PERMIT STAND

PRINCIPAL OPERATOR NAME: Otis Phillips TREATMENT CERTIFICATION # AND GRADE: 10506 LEVEL 4
 SIGNATURE: _____ COLLECTIONS CERTIFICATION # AND GRADE: 7848 LEVEL 1
 During this reporting period did all monitoring data & sampling frequencies meet permit requirements & limits (if "no", explain)? YES NO
 During this reporting period were there unanticipated bypasses or upsets which exceeded any effluent limits (if "yes", explain)? NO YES
 During this reporting period was there any collections system overflows (if "yes" explain)? NO YES

