

PLANT INFLUENT				PLANT EFFLUENT @DMS																		REMARKS			
DAY	INF. MGD	EFF. MGD	Molalla River CFS	pH	BOD mg/L	TSS mg/L	Temp	pH	Max Temp	Min DO	NH3	BOD mg/L	BOD % Rem	BOD Disch. lbs	TSS mg/L	TSS % Rem	TSS Disch. Lbs	Chlorine Used lbs	Cl2 Res	Total Colif	Turbidity	MOL 1400-DO	River 1800 Temp	RAIN inch	Day
1	0.921			7.2	169	151	15.1															11.5	11.4	0.60	1
2	1.293			6.9			15.0															11.2	10.7	0.40	2
3	1.290			7.2	151	120	14.9															11.9	10.2	0.20	3
4	1.147			6.8			14.4															11.9	10.7	0.15	4
5	1.084																							0.00	5
6	1.057																							0.00	6
7	0.994			7.1			15.3															10.9	14.5	0.00	7
8	0.974			7.0	150	148	15.5															10.7	15.3	0.00	8
9	0.930			7.2			15.4															11.5	14.6	0.00	9
10	0.925			7.0	139	140	15.6															11.0	13.9	0.00	10
11	0.948			7.2			15.7															11.2	13.1	0.00	11
12	0.982																							0.07	12
13	0.948																							0.01	13
14	0.929			7.0			15.9															10.7	13.0	0.00	14
15	0.925	0.446		7.2	163	173	16.1											19				10.5	16.0	0.00	15
16	0.886	0.369		7.2			16.3											16				10.2	16.2	0.00	16
17	0.861	0.514		7.0	130	170	15.9											18			0.68	10.4	16.2	0.00	17
18	0.864	0.959		7.1			16.2	7.3			7.6							31	0.04		1.17	10.3	15.9	0.08	18
19	0.883	0.724						7.3										25	0.65	<1	1.48			0.01	19
20	0.956	0.206																7		<1	2.01			0.15	20
21	0.911	0.609		7.3			16.3	7.1										18	0.70	<1	0.68	11.3	12.0	0.00	21
22	0.862	1.003		7.2	177	171	16.3	6.9			9.9							30	1.00	<1	0.60	11.9	12.5	0.00	22
23	0.823	0.967		7.3			16.5	6.7										36	1.20	<1	0.65	10.6	14.8	0.01	23
24	0.830	1.005		7.1			16.8	6.7			10.8							33	1.40	<1	0.81	10.5	17.3	0.00	24
25	0.825	1.003		7.2			17.4	7.1										37	1.00	<1	0.84	10.8	15.4	0.00	25
26	0.824	0.957																32	1.00	<1	0.74			0.00	26
27	0.823	0.871																31	1.20	<1	0.61			0.00	27
28	0.865	0.834																29	1.00	<1	0.58			0.00	28
29				7.3			18.2	7.0			11.4								1.00						29
30																									30
31																									31
Total	26.560	10.467																362						1.68	TOTAL
MAX	1.293	1.005		7.3	177	173	18.2	7.3			11.4	0.0	0	0	0.0	0	0	37	1.40					0.60	MAX
MIN	0.823	0.206		6.8	130	120	14.4	6.7			7.6	0.0	0	0	0.0	0	0	7	0.04					0.00	MIN
AVG	0.949	0.748	#DIV/0!	7.1	154	153	15.9	7.0	#DIV/0!	#DIV/0!	9.9	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	26	0.93	#DIV/0!	0.9	11.0	13.9	0.06	AVG
T STAND								6-9				10mg/L	80%	160 lbs/day	10mg/L	80%	160 lbs/day			2.2	2.0/Daily Average				PERMIT STAND

PRINCIPAL OPERATOR NAME: Otis Phillips TREATMENT CERTIFICATION # AND GRADE: 10506 LEVEL 4
 SIGNATURE: _____ COLLECTIONS CERTIFICATION # AND GRADE: 7848 LEVEL 1

During this reporting period did all monitoring data & sampling frequencies meet permit requirements & limits (if "no", explain)? YES NO
 During this reporting period were there unanticipated bypasses or upsets which exceeded any effluent limits (if "yes", explain)? NO YES
 During this reporting period was there any collections system overflows (if "yes" explain)? NO YES

