



TABLE A

"A"	4"	6"	8"	10"	12"	15"	18"	21"	24"	30"	36"	42"	48"	54"	60"	66"	72"
"B"	6"	6"	6"	6"	6"	D/2	24"	24"	24"	24"	24"						
"C"	6"	6"	6"	6"	6"	6"	6"	6"	6"	8"	10"	12"	12"	14"	16"	16"	18"

BACKFILL IN STREET AREAS

1. IF S/W IS AGAINST CURB, FILL ROCK TO BACK OF S/W.
2. IF S/W IS NOT AGAINST CURB, FILL ROCK 2' BACK FROM CURB.
3. 1 2" TEE CUT TO BE MADE AFTER INSTALLATION AND COMPACTION OF CRUSHED AGGREGATE.
4. RESURFACE WITH CLASS "C" ASPHALT CONCRETE. MINIMUM THICKNESS TO BE 3" OR EXISTING THICKNESS PLUS 2", WHICH EVER IS GREATER, (NOT TO EXCEED A TOTAL THICKNESS OF 6").
5. FOR ARTERIAL, COLLECTOR, ODOT OPERATED, OR WHEN PIPE COVER IS 2 FEET OR LESS, BACKFILL WITH CLSM PER ODOT STANDARD SPECIFICATION 00442.

Detail Drawing may not be altered or changed in any manner except by the Public Works Director. It is the responsibility of the user to acquire the most current version.

CITY OF MOLALLA
DEPARTMENT OF PUBLIC WORKS



STANDARD TRENCH DETAIL
ASPHALT PAVEMENT

DRAWN BY	PDG	01/2016
CHECKED BY	JC	01/2016

S-2140