



1. BEDDING FOR SERVICE LINES SHALL BE MIN. 6-INCHES OF 3/4"-0 CRUSHED ROCK.
2. TAPPING OF SEWER MAINS TO BE INSPECTED BY CITY FORCES.
3. IN NEW SUBDIVISIONS OR FOR UNUSED STUBS, MARK END OF SERVICE WITH PAINTED 2 x 4 STAKE (WHITE FOR STORM, GREEN FOR SANITARY). MARKER SHALL EXTEND AT LEAST 2 FEET ABOVE FINISHED GRADE. USING BLACK INDELIBLE MARKER, INDICATE DEPTH FROM TOP OF BOARD AND TYPE (SS FOR SANITARY, SD FOR STORM DRAIN).
4. INSTALL A CONTINUOUS 14 GAUGE INSULATED COPPER TRACER WIRE ADJACENT TO SEWER LATERAL BETWEEN THE SEWER MAIN AND CLEANOUT AT BUILDING. (USE GREEN INSULATION FOR SEWER, WHITE FOR STORM)
5. ADJACENT SERVICE LINES TO HAVE 18" MINIMUM HORIZONTAL SEPARATION AT THE MAIN.
6. ANGLE AND BEND MAY BE REDUCED TO 22.5° WITH SPECIFIC APPROVAL FROM THE PUBLIC WORKS DIRECTOR.

Detail Drawing may not be altered or changed in any manner except by the Public Works Director. It is the responsibility of the user to acquire the most current version.

CITY OF MOLALLA DEPARTMENT OF PUBLIC WORKS



SERVICE LATERAL DETAIL

DRAWN BY	PDG	01/2016
CHECKED BY	JC	01/2016

S-2175