



NOTES:

1. VALVE BOX TO BE CONCRETE ENCASED AS SHOWN, IF NOT IN PAVED AREA.
2. BLOW-OFF UNIT SHALL BE BACKFILLED WITH 3/4"-0 CRUSHED ROCK AND COMPACTED TO 95% OF MAX. DENSITY DETERMINED BY AASHTO T-180.
3. BLOW-OFF NOT TO BE LOCATED IN GUTTER OR DITCH.
4. 2" BLOW-OFF FOR USE ON PIPE SIZES UP TO 12 INCHES IN DIAMETER.
5. 2" BLOW-OFF FOR USE ON PIPE SIZES UP TO 6 INCH FOR PERMANENT DEAD ENDS AND UP TO 8 INCH FOR TEMPORARY DEAD ENDS OR PLANNED FUTURE EXTENSIONS OF THE MAIN.

Detail Drawing may not be altered or changed in any manner except by the Public Works Director. It is the responsibility of the user to acquire the most current version.

**CITY OF MOLALLA
DEPARTMENT OF PUBLIC WORKS**



**2" BLOW-OFF DETAIL
12" & SMALLER WATERLINE**

DRAWN BY	PDG	01/2016
CHECKED BY	JC	01/2016

W-3075