

DAY	PLANT INFLUENT				PLANT EFFLUENT : REUSE																	MOL 1400- DO	River 1800 Temp	RAIN inch	REMARKS	Day				
	INF. MGD	EFF. MGD	Molalla River CFS	pH	BOD mg/L	TSS mg/L	Temp	pH	Max Temp	Min DO	NH3	BOD mg/L	BOD % Rem	BOD Disch. lbs	TSS mg/L	TSS % Rem	TSS Disch. Lbs	Chlorine Used lbs	Field Cl2 Residual	Total Colif	Turbidity									
1	0.760																					9.8	18.1	0.00	Plant Off.	1				
2	0.742			7.4	323	402	20.1															9.6	19.1	0.00		2				
3	0.734			7.3			20.8															9.6	19.2	0.00		3				
4	0.722			7.4	255	387	20.7															9.5	19.2	0.00		4				
5	0.703			7.3			20.7																	0.00		5				
6	0.712																							0.00		6				
7	0.761																							0.00		7				
8	0.707			7.7			22.2															9.5	19.8	0.00		8				
9	0.708			7.6	277	354	20.3															8.5	20.9	0.00		9				
10	0.695			7.6			20.7															8.6	19.7	0.00		10				
11	0.707			7.5	235	319	20.5															8.7	20.8	0.00		11				
12	0.694																					8.9	20.6	0.00		12				
13	0.711																							0.00		13				
14	0.720	0.461																						0.00	Start Plant 12:00. Filling FM = .461MG	14				
15	0.697	1.350		7.7			20.7	6.8														62	0.70	3.1	1.2	9.0	20.1	0.00	Filling FM = .189MG. Start Irrigation 10:00	15
16	0.701	1.348		7.5		232	20.7	7.0														73	0.70	<1	1.0	9.5	19.9	0.00		16
17	0.703	1.316		7.4			20.8	6.9														63	0.90		1.1	9.7	19.8	0.00		17
18				7.4			20.7																					0.00		18
19																														19
20																														20
21																														21
22																														22
23																														23
24																														24
25																														25
26																														26
27																														27
28																														28
29																														29
30																														30
31																														31
Total	12.177	4.475																231											0.00	TOTAL
MAX	0.761	1.350		7.7	323	402	22.2	7.0			0.0	0.0	0	0	0.0	0	0	73	0.90									0.00	MAX	
MIN	0.694	0.461		7.3	235	232	20.1	6.8			0.0	0.0	0	0	0.0	0	0	33	0.70									0.00	MIN	
AVG	0.716	1.119		7.5	273	339	20.7	6.9										58	0.77			1.1	9.2	19.8	0.00			0.00	AVG	
PERMIT STAND								6- 9														2.2/ 100ml	2.0 Daily Average						PERMIT STAND	

PRINCIPAL OPERATOR NAME: Otis Phillips TREATMENT CERTIFICATION # AND GRADE: 10506 LEVEL 4  
 SIGNATURE: \_\_\_\_\_ COLLECTIONS CERTIFICATION # AND GRADE: 7848 LEVEL 1

During this reporting period did all monitoring data & sampling frequencies meet permit requirements & limits (if "no", explain)? YES NO  
 During this reporting period were there unanticipated bypasses or upsets which exceeded any effluent limits (if "yes", explain)? NO YES  
 During this reporting period was there any collections system overflows (if "yes" explain)? NO YES

